

**Corrigendum-01 for Tender No. - ITPS /Unit -3&4 /2019-2020/144 dtd.19.09.2019**

| SI No. | Existing Description of Item   | Amended Description of Item  |
|--------|--|--|
| 4      | 4.5 Kg cap CO2 extinguisher CC/WBS: IB34CP1501M0801F   | Co2 Type Fire Extinguisher-4.5Kg. capacity. Co2 type Fire Extinguisher 4.5kg capacity IS 15683 marked extinguisher. with Brass forged Screw down / squeeze lever type valve, initial gas charged as per IS 15222, Rubber braided discharge hose, Rubber grip & Horn complete with accessory including the carrying handle as per IS:15683 with 'BIS' Mark, MTC & PESO certificate. Wall mounting bracket with screw. FIRE RATING as per IS 15683. Performance test certificate shall be submitted.   |
| 6      | CO2 extinguisher 9 kg. capacity trolley mounted type IS 16018 marked. Filled with Carbon dioxide fire extinguishing media 'CO2 quality shall be as per the Indian standard IS: 522.Complete with all parts i.e. trolley, wheel, discharge hose (For un controlled discharge with WP 150 bar). ISI certificate with hydro test certificate need to be submitted.<br><br>Quality certificate for extinguishing media need to be submitted. | Carbon Dioxide type fire extinguisher 22.5 kg. capacity. Complete with trolley with wheel, carrying handle & discreet hose with horn. The discreet hose with horn shall be 2.5 to 3-meter-long equipped with rubber grip handle & shall be pressure rated as per the IS for uncontrolled discharge. The extinguisher shall be ISI marked (IS 2878 or as updated) & PESO approved type. the Agent filled shall be as per IS for fire Cabon dioxide for firefighting & shall satisfy the purity requirement as per ISI. Performance test certificate, PESO certificate shall be submitted  |
| 7      | Mech foam extinguisher (9 ltr) CC/WBS:IB34CP1501M0801F   | Foam Type CO2 cartridge operated fire extinguishers 9 lit. capacity marked with IS: 15683:2006and ISI marked. Filled with ISI certified 3% AFFF type firefighting foam solution. Complete with all Components i.e. cap, Inner component, ISI marked Gas cartridge, Discharge Hose etc. Wall Hanging bracket to be supplied with the equipment. Painted with Fire red color ( IS-5 Shade 536 / 537). Punched with ISI and Serial no, Hydro test date & pressure at the bottom ring of the fire extinguisher. ISI certification need to be submitted for technical evaluation & Hydro test, quality certificate, for the fire extinguisher need to be submitted with the delivery. |

**N.B: All other stipulations/conditions of NIT No. ITPS/Unit 3&4/2019-2020/144, dt.19/09/2019 shall remain unaltered. This corrigendum can be seen from website [www.opgc.co.in](http://www.opgc.co.in)**

**Sd/-  
AGM-SCM**