



ODISHA POWER GENERATION CORPORATION LIMITED
IB THERMAL POWER STATION
At/PO: BANHARPALI, DIST: JHARSUGUDA – 768 234 (ODISHA)

CORRIGENDUM NOTICE-I; Dt. 18.09.2018
To NIT No.2018-19/20(P), Dt.14.08.2018

PURCHASE TENDER :

(Telephone; 06645-289354/356; Telefax: (06645)289355 Email: purchase@opgc.co.in; bhadoo.jojowar@opgc.co.in; bn.das@opgc.co.in; sidharth.patnaik@opgc.co.in)

This is to bring to the notice of all intending prospective bidders and to clarify the technical specification through this Corrigendum Notice-I that **(A) the bid submission and opening date against the following NIT is extended as mentioned below in the table.**

| Sl. No. | NIT No/Date | Description | Qty. | Due date of bid submission /opening | Extended Bid submission/ Opening Date. | Single bid / two bid |
|---------|---|------------------------------|----------------------|-------------------------------------|--|----------------------|
| 3 | NIT No. 2018-19/20 (P) dt.14/08/2018 | Supply of HDPE pipes & bends | As per tech. details | 03.09.2018/ 03.09.2018 | 08.10.2018/ 08.10.2018 | Two Bid |

(i) Time of submission/Receipt of bids: up to 15:00Hrs; (ii) Time of Bid Opening: 15:30Hrs.

(B) The specification at "Sl.No.2:Technical details" under Techno-commercials bid PART-I may please be read and understood as mentioned in the table below.

| SL No. | Description | Detailed Technical Description | Qty. | UoM. |
|--------|--|--|------|------|
| 01 | HDPE pipe + Collar + flange -250mm OD pipe/ 6 Metre length/ 18.4mm thickness, as per IS 4984 : 1995/ IS 4984: 2016, | HDPE pipe with collar & Flange, Pipe Size: 250 mm Outer diameter Thickness of pipe: 18.4 mm Length of pipe: 6 metre Class: PN 10 (10 kg/cm2) Pipe material: High Density Poly Ethylene Pipe Material grade : PE 100 Flange material : GI, Flange Thickness : 20 mm, Flange Hole size : 19 mm, No. of Holes of flange: 08 | 379 | EA |
| 02 | HDPE pipe Bend + Collar + flange - 250mm OD pipe, 90 Degree bend, 18.4mm thickness, as per IS 4984 : 1995/ IS 4984: 2016 | HDPE pipe bend with collar & Flange, Pipe Size: 250 mm Outer diameter Thickness of pipe: 18.4 mm Length of bend pipe: short bend Class: PN 10 (10 kg/cm2) Pipe material: High Density Poly Ethylene Pipe Material grade : PE 100 Flange material : GI, Flange Thickness : 20 mm, Flange Hole size : 19 mm, No. of Holes of flange: 08 | 30 | EA |

| | | | | |
|----|--|--|-----|----|
| 03 | HDPE pipe + Collar + flange -125mm OD pipe/ 6 Metre length/ 9.2 mm thickness, as per IS 4984 : 1995/ IS 4984: 2016 | HDPE pipe with collar & Flange, Size: 125 mm Outer diameter Thickness of pipe: 9.2 mm Length of pipe: 6 metre Class: PN 10 (10 kg/cm2) Pipe material: High Density Poly Ethylene Flange material : GI, Flange Thickness : 20 mm, Flange Hole size : 19 mm, No. of Holes of flange: 08 | 380 | NO |
| 04 | HDPE pipe Bend + Collar + flange - 125mm OD pipe, 90 Degree bend, 9.2 mm thickness, as per IS 4984 : 1995/ IS 4984: 2016 | HDPE pipe bend with collar & Flange, Size: 125 mm Outer diameter, Thickness of pipe: 9.2 mm Length of bend pipe: short bend, Class: PN 10 (10 kg/cm2) Pipe material: High Density Poly Ethylene Flange material : GI, Flange Thickness : 20 mm, Flange Hole size : 19 mm, No. of Holes of flange: 08 | 30 | NO |

N.B: All other stipulations/conditions of the NIT-20(P), Dt.14.08.2018 shall remain unaltered.

Sd./- AGM -SCM

(Email: bkmishra@opgc.co.in; Landline No. 06645-289703)

SAFE & CLEAN POWER IS OUR COMMITMENT