

**TECHNICAL SPECIFICATION
FOR
CABLING REROUTE, GROUNDING AND
LIGHTNING PROTECTION SYSTEM**

CONTENT

CLAUSE NO.	DESCRIPTION	PAGE NO.
1.00.00	SCOPE OF WORK	V-IIF-2/S-VIII : 1
2.00.00	SCOPE OF SUPPLY	V-IIF-2/S-VIII : 1
3.00.00	GENERAL REQUIREMENTS	V-IIF-2/S-VIII : 3
4.00.00	DESIGN CRITERIA	V-IIF-2/S-VIII : 4
5.00.00	SPECIFIC REQUIREMENTS - SUPPLY	V-IIF-2/S-VIII : 7
6.00.00	METHODS AND WORKMANSHIP	V-IIF-2/S-VII : 11
7.00.00	INSTALLATION	V-IIF-2/S-VIII : 12
8.00.00	TESTS	V-IIF-2/S-VIII : 20
9.00.00	DRAWINGS, DATA & MANUALS	V-IIF-2/S-VIII : 21

ATTACHMENTS

		Mantra Udyog
--	--	--------------

ANNEXURE-A


NOTES AND DETAILS FOR
CABLING SYSTEM

V-II-F2/S-VIII/Annx-A : 22

ANNEXURE-B

NOTES AND DETAILS FOR
GROUNDING AND LIGHTING
PROTECTION SYSTEM

V-IIF-2/S-VIII/Annx-B : 26

	Odisha Power Generation Corporation Ltd.	Technical Specification for cable reroute, grounding and lighting protection	IB TPS – 2 X 660 MW Units 3 & 4, Jharsuguda, Odisha
---	--	--	---

TECHNICAL SPECIFICATION FOR CABLING, GROUNDING AND LIGHTNING PROTECTION SYSTEM

1.00.00 SCOPE OF WORK

1.01.00 The Scope of Work covers design, engineering, manufacture, assembly, testing at manufacturer's works/laboratory, supply, delivery, material and accessories related to complete and efficient erection, testing and commissioning of all cabling, electrical grounding works and lightning protection system. The erection, commissioning and testing of the above systems shall be carried by Erection contractor appointed by Buyer. The scope shall broadly cover, but not be limited to:

1. Workshop Building
2. Reroute of existing cable form raw water transformer to Raw water pump house in order to make space available for the construction of new work shop building.

2.00.00 SCOPE OF SUPPLY


2.01.00 The scope of supply shall include but not be limited to the followings

2.01.01 Timely procurement and transportation to site in properly packed condition of all materials and miscellaneous items required to complete under this specification.

These materials and miscellaneous items shall include but not be limited to the following :

- a) Galvanised steel pre-fabricated cable trays, coupler plates, nuts, bolts & washers, reducers, covers, wall brackets, hanger clamps, straight run, elbows, bends, etc.
- b) Galvanised steel rigid/flexible conduits and accessories, ferrules, lugs, glands, terminal blocks, galvanised sheet steel junction boxes, cable fixing clamps, nuts & bolts etc. as required.
- c) Cable termination and jointing kits as necessary.
- d) All necessary erection materials, consumables and sundry items including arc welding rods to complete the installation for satisfactory and trouble free operation.
- e) Mild steel rods, galvanised steel flats, galvanised steel rods, lead coated copper tube suitably brazed with galvanised steel Bend ring galvanised steel wires etc. required for grounding and lightning protection system shall be supplied in standard lengths.

		Mantra Udyog
--	--	--------------

	Odisha Power Generation Corporation Ltd.	Technical Specification for cable reroute, grounding and lighting protection	IB TPS – 2 X 660 MW Units 3 & 4, Jharsuguda, Odisha
--	--	--	---

- f) Any item of works or erection materials which have not been specifically mentioned but are necessary to complete the work involved shall be deemed to be included in the scope of this specification and shall be furnished by the Seller without any extra charge to the Buyer.

2.01.02

a) **Main Ground Mat**

Supply of 40 mm dia M.S. rod as below grade grounding conductors for Main Ground Mat with suitable pigtails for connection with existing plant ground grid and other Balance of Plant system.

b) **Grounding Electrode**

Supply of 40mm. diameter 3000 mm long M.S. rod as grounding electrode for connecting the Grounding Mat with ground at suitable point as per the requirement of the system.

c) **Column Grounding**

i) **Concrete Columns**

Supply of 1 no. 40 mm. dia. M.S. rod from grounding mat to each concrete columns of the Main Plant area along with short GS flat to edge angles required for fixing the rod with the column above ground

ii) **Steel Columns**

Supply of 1 No. 40 mm diameter M.S. rod from grounding mat to each steel columns of the Main Plant area along with short GS flat to edge angles required for fixing the rod with the column above ground.

d) **Risers**

Supply of all risers from underground mat to above ground levels where the ends shall be left free for connecting to the equipment. Each riser shall be 1 No. 40 mm dia. M.S. rod and Minimum 300 mm above grade level/concrete floor level.

- e) All other ancillary works in connection with the items of supply described above which are not specifically mentioned but are necessary to complete the work, shall be under the scope of this specification.

2.02.00

All materials and accessories to be supplied by the Seller shall be brand new ones of reputed make.

2.03.00


Necessary drawings, data sheets and Technical leaflets on each piece of material.

2.04.00

Scope of Services

The equipment and system supplied by Seller shall be installed by erection contractor appointed by Buyer. The Technical Advisory Personnel of Seller

		Mantra Udyog
--	--	--------------

	Odisha Power Generation Corporation Ltd.	Technical Specification for cable reroute, grounding and lighting protection	IB TPS – 2 X 660 MW Units 3 & 4, Jharsuguda, Odisha
--	--	--	---

shall be responsible for witnessing and approval of all critical erection works. The Seller shall review the installation requirements mentioned and incorporate necessary requirements in the design.

The scope includes but is not limited to the followings;

2.04.01 The items of erection work shall be performed with respect to the following equipment/materials :

- a) Power Cables
- b) Cables laid directly buried in ground
- c) Control, instrument and special cables
- d) Entire cable tray and cable shaft arrangements inside Power House & other buildings under Main Plant package as well as outdoor cable bridges and all associated civil and structural works including foundation and cable trenches.
- e) Erection of Grounding system.
- f) Erection of lightning Protection system.

3.00.00 **GENERAL REQUIREMENTS**

3.01.00 **Codes and Standards**

3.01.01 All cable and materials shall be designed, manufactured and tested in accordance with the latest applicable Indian Standards (IS) and IEC (Refer Annexure-D, Section-I, Volume-II F1) except where modified and/or supplemented by this specification.

3.01.02 Cable and material conforming to any other standard, which ensures equal or better quality, may be accepted. In such case the Seller shall prove details how his standard fulfills Buyer's requirement and shall furnish, copies of the English version of the standard adopted shall be submitted.

3.01.03 The electrical installation shall meet the requirements of Indian Electricity Rules 1956 as amended up to date and relevant IS Code of Practice. In addition, other rules and regulations applicable to the work shall be followed.

3.02.00 **Material Supply Schedule**


3.02.01 The material supply schedule shall be submitted by the Seller for preparation of erection schedule by Buyer's appointed contractor.

4.00.00 **DESIGN CRITERIA**

4.01.00 **Grounding System**

4.01.01 The main objectives of grounding system are to :

		Mantra Udyog
--	--	--------------

	Odisha Power Generation Corporation Ltd.	Technical Specification for cable reroute, grounding and lighting protection	IB TPS – 2 X 660 MW Units 3 & 4, Jharsuguda, Odisha
---	--	--	---

- a) Provide safety to personnel from contact of dangerous potential caused by ground fault.
- b) Ensure sufficient grounding current for effective relaying.
- c) Stabilize circuit potential with respect to ground.

4.01.02 In order to meet the above objectives, ground grid mesh shall be provided for the main plant complex. viz. transformer yard adjacent to power house building, power house building and boiler area up to stack, auxiliary buildings etc and provision shall be kept for connecting the grid with switchyard and other BOP areas at atleast two points.

All electrical equipment, non current carrying metal parts, structures, building steel, lightning protection system, generator/transformer neutrals shall be connected to this station ground grid.

The major aspects to be considered for grounding system design are given below :

4.01.03 **Ground Grid Conductor**

- a) Ground grid conductor of mild steel rod shall be used.
- b) The minimum conductor section is determined on the basis of ground fault current. This section is then increased by an allowance to account for the soil corrosion loss of 0.3 mm per year over the design life of 30 years.


4.01.04 **Underground Grid**

- a) The ground grid mesh is designed to keep the touch and step voltages within safe limits as per recommendation of IEEE 80.
- b) The ground grid conductors shall be buried in earth at a minimum depth of 1000 mm. The length of ground conductors below earth shall be sufficient to ensure a ground resistance less than one (1) ohm.
- c) The ground grid conductor shall be so laid as to provide short and direct connection to building steel and major electrical equipment.
- d) Ground rods shall be provided at the points where system neutrals/lightning protections are connected to the ground grid.
- e) All ground grid conductor connections shall be welded type.
- f) New ground grid shall be connected with the existing ground grid at least at two (2) points.

4.01.05 **Above Ground Connections**

- a) Galvanised steel flats shall be used for all connections above earth.

		Mantra Udyog
--	--	--------------

	Odisha Power Generation Corporation Ltd.	Technical Specification for cable reroute, grounding and lighting protection	IB TPS – 2 X 660 MW Units 3 & 4, Jharsuguda, Odisha
---	--	--	---

- b) Inside building, ground conductors shall be run for each floor supported on building steel and/or cable trays. These ground conductors in turn shall be connected to the station ground grid through riser (at least two) coming up along building columns/cable shafts.
- c) Two separate and distinct ground connections shall be provided for each electrical equipment in compliance with I.E. Rules.
- d) All connections above ground shall be welded type except connection to equipment/structures, which shall be bolted type.

4.01.06 **Equipment Ground Lead**

Equipment ground connections shall be sized to carry the available ground fault current. Considerations shall also be given to mechanical ruggedness of the connections and to limit the number of sizes.

4.01.07 The minimum ground conductor sizes for various equipment and structures are given in Annexure-B.

4.02.00 **Lightning Protection System**

4.02.01 The main purposes of lightning protection system are to :

- a) Provide protection to structures from lightning strokes.
- b) Provide a low resistance-conducting path to lightning discharge.


4.02.02 Lightning protection shall be provided for Power House building, auxiliary buildings , and other structures.

4.02.03 Lightning protection shall also be provided for building/ structures where the overall rise factor exceeds 10^{-6} as per IS:2309..

4.02.04 For metal structures which are electrically continuous down to the ground level, no lightning protection is required except adequate grounding connections.

4.02.05 **System Design**

- a) Air termination network with down conductors and earthing electrodes shall be provided on the basis of IS Code of Practice.
- b) Horizontal air termination shall be so laid out that no part of the roof shall be more than 9 meters from the nearest conductor.
- c) Shielding angle for one vertical air termination shall be 45 degrees. For more than one rod, shielding angle between the rods shall be taken as 60 Degrees.
- d) Down conductors shall run along the outer surfaces of the building and shall have a test joint about 1500 mm above ground.

	Odisha Power Generation Corporation Ltd.	Technical Specification for cable reroute, grounding and lighting protection	IB TPS – 2 X 660 MW Units 3 & 4, Jharsuguda, Odisha
--	--	--	---

- e) An earth electrode shall be provided at the connection point of the down conductor with the station ground.
- f) Galvanised steel rods and flats shall be generally used for air termination and connections. All connections shall be welded type.

4.03.00 **Cabling System**

4.03.01 Design and layout of cabling system shall be carried out in such a way as to provide a reliable and assured electric power supply system to all station auxiliaries. The Seller shall design and supply the items considering the following basis of cabling system inside the Main Plant area.

4.03.02 Cable routing shall be done on unit basis as far as possible.

4.03.03 Cables shall generally be laid on cable trays either in concrete trenches or overhead supported from building steel/structures. Cables shall be run in concrete trenches in those electrical rooms at ground level, which are without any spreader room below.

In indoor pumps, mechanical equipment areas overhead cable trays shall generally be used local concrete trenches shall be used outdoor in transformer yard adjacent to Power House Row 'A' for cable routing.

4.03.04 For inter plant connections, the cables shall be routed through an overhead cable bridge pipe cum cable bridge. For isolated but long outdoor cable route with very few cables of 3/4 nos., the cables may be directly buried.

4.03.05 For underground crossing of railways, road etc. additional protection shall be provided in form of hume pipe or concrete encased rigid steel conduits (duct bank).

4.03.06 A.C. and D.C. circuit shall not be run in same cable. Further, separately fused circuit shall run in separate cables.

4.03.07 Cables for redundant equipment system shall be run in separate trays, as far as possible.


4.03.08 Layout of cabling work shall be prepared keeping in view all necessities and requirements of fire fighting codes for Generating Stations having an adverse industrial environment.

4.03.09 Suitable embedded steel inserts shall be provided on wall/floor/ ceiling surfaces for welding of cable tray bracket in order to make the cable tray system withstand horizontal/vertical accelerations due to seismic forces for indoor trays and also wind load for outdoor trays such as on Boiler platforms in addition to normal tray cable loadings.

4.03.10 All erection work to be carried out under this specification shall conform to the notes and details given in Annexure-A to this specification.

5.00.00 **SPECIFIC REQUIREMENTS - SUPPLY**

		Mantra Udyog
--	--	--------------

	Odisha Power Generation Corporation Ltd.	Technical Specification for cable reroute, grounding and lighting protection	IB TPS – 2 X 660 MW Units 3 & 4, Jharsuguda, Odisha
---	--	--	---

5.01.00 **Equipment and Material**

5.01.01 Equipment and material shall comply with description, rating, type and size as detailed in this specification, drawings and annexures.

5.01.02 Equipment and materials furnished shall be complete and operative in all details.

5.01.03 All accessories, fittings, supports, hangers, anchor bolts etc. which form part of the equipment or which are necessary for safe and satisfactory installation and operation of the equipment shall be furnished.

5.01.04 All parts shall be made accurately to standard gauges so as to facilitate replacement and repair. All corresponding parts of similar equipment shall be interchangeable.

5.02.00 **Pre-fabricated Cable Trays**

5.02.01 Cable trays shall be pre-fabricated ladder type sheet steel with hot dip galvanising furnished in standard length of 2.5 metres.

5.02.02 Cable trays shall be of standard width specified in Annexure-A and drawings.

5.02.03 Cable trays shall be complete with all necessary hot dip galvanised sheet steel accessories such as coupler plates, ground continuity connections, nuts, bolts, washers, hangers, clamps etc. Also horizontal/vertical bends, horizontal/vertical Tee, Reducers, Horizontal cross-pieces, protective covers shall be supplied along with straight runs in order to take care of cable tray alignments in different routes.


5.02.04 All fittings like horizontal/vertical elbow, horizontal crosspiece, reducer, horizontal tee etc. should be prefabricated.

5.02.05 Cable trays, fittings & accessories as well as elbows, reducers, tees, crosses etc. shall be fabricated out of 14 gauge (2 mm thick) hot rolled mild steel sheets.

5.02.06 Seller shall supply 14 gauges (2 mm thick) perforated type hot rolled mild steel sheet covers for vertical cable shafts up to a height of 2.5 metres from floor level. The perforated covers used for the vertical raceways may be of one or more pieces along the width of the raceway, depending on the width of the raceway and shall be bolted to the structural framework of the raceway.

5.02.07 The cable trays, fittings and accessories including all bolts, nuts, screws, washers etc. shall be hot dip galvanised after fabrication as per IS:2629. Galvanising shall be uniform, clear, smooth and free from acid spots. Should the galvanising of the samples be found defective, the entire batch of steel shall have to be regalvanised at Seller's cost.

The amount of zinc deposited shall not be less than 610 gms per square metre of surface area and in addition the thickness of the zinc deposit at any spot whatsoever, shall not be less than 75 microns. The Buyer reserves the right to measure the thickness of zinc deposit by Elcometer or any other instrument and

	Odisha Power Generation Corporation Ltd.	Technical Specification for cable reroute, grounding and lighting protection	IB TPS – 2 X 660 MW Units 3 & 4, Jharsuguda, Odisha
---	--	--	---

reject any component, which shows thickness of zinc at any location to be less than 75 microns.

5.02.08 Each 2.5M long section of all types of cable trays & each fittings like elbow, tees, crosses etc. shall be provided with two nos. hot dip galvanised side coupler plates & associated bolts, nuts and washers on each side.

5.02.09 The Seller shall perform all tests necessary to ensure that the material and workmanship conform to the relevant standards (Refer Annexure-D, Section-I, Volume-II F1) and that such tests are adequate to demonstrate that the equipment shall comply with the requirement of this specification.

The tolerance on dimensions shall be in accordance with appropriate Indian Standards. The extent of the tests shall include but not be limited to the following:

Deflection Test

A 2.5 metre straight section of each type of cable trays shall be simply supported at the two ends. A uniformly distributed load of 100 Kg per metre shall be applied along the length of the tray. The maximum deflection at mid span shall not exceed 7 mm.

5.02.10 For other details refer CABLING NOTES AND DETAILS annexed to this specification.

5.03.00 Conduits and Accessories

5.03.01 Conduits shall be of rigid steel, hot-dip galvanised, furnished in standard length of 5 metres, threaded at both ends.

5.03.02 Conduits diameter upto and including 25mm size shall be of 16 SWG and conduits above 25 mm diameter shall be of 14 SWG. Minimum diameter of conduits shall be 20 mm.


5.03.03 Each piece of conduit shall be straight, free from blister and other defects, internal surface shall be of smooth finish and covered with capped bushings at both ends.

5.03.04 The Seller shall provide and install all rigid steel conduits, mild steel pipes, flexible conduits rigid PVC pipes etc. complete with accessories such as tees, bends, adapters, locknuts, pull boxes, conduit plugs, caps etc as required for the cabling work.

5.03.05 Steel conduits with interior coating of silicon epoxy ester for ease of wire/cable pulling shall be seamed by welding and flow-coat metal conduit/hot-dip galvanised. These shall be supplied in standard length of 5M with minimum wall thickness as specified in IS:9537. In chemical handling areas, Battery Room etc., the exterior surface shall be further coated with chromate and polymer for better resistance to corrosion. Conduits, fittings & accessories shall have ISI mark.

5.03.06 For sizes above 63 mm mild steel pipes with necessary fittings & accessories shall be provided. Pipes shall be manufactured by electric welding process.

		Mantra Udyog
--	--	--------------

	Odisha Power Generation Corporation Ltd.	Technical Specification for cable reroute, grounding and lighting protection	IB TPS – 2 X 660 MW Units 3 & 4, Jharsuguda, Odisha
--	--	--	---

These pipes shall be of heavy duty class as per IS:1239 and shall have ISI mark. Pipes shall be supplied in lengths of approximately 5 metres. Pipes, fittings & accessories shall be hot dip galvanised both on inside and outside.

5.03.07 Flexible conduits shall comply with IS:3480. They shall be made with bright, cold-rolled, annealed and electro-galvanised mild steel strips. Flexible conduits shall be used between embedded conduits/pipes and the motor terminals. Flexible conduits shall also be used between fixed conduit and any equipment terminal boxes where vibration is anticipated or equipment that require regular removal.

5.03.08 Rigid PVC conduits conforming to IS:4985 shall generally be used for control & instrumentation cables in some areas where cable trays do not exist and where the runs are straight ones generally the PVC pipes with special Bell Mouthing shall be of 110 mm,160 mm & 200 mm outside diameter and shall be suitable for working pressure of 6 kg/sq. cm. The length of each pipe shall be 5 to 6 metres. Necessary fittings & accessories as may be required for the installation shall also be provided.

5.04.00 **Junction Boxes**

5.04.01 Junction boxes shall be of 16 SWG sheet steel hot-dip galvanised, out-door type, dust vermin and damp proof, generally conforming to IP 55. Junction boxes for accommodating cables upto 3Cx16 sq.mm to be FRP instead of sheet steel for indoor and outdoor.

5.04.02 Junction boxes shall be complete with neoprene gasketed inspection cover, conduit knock out, terminal blocks and painted with one coat of red oxide primer and two finishing coats of light grey (shade 631 of IS-5) synthetic enamel paint.

5.04.03 Junction boxes for outdoor use shall be weather proof IPW-55 and those for hazardous location shall be flame-proof type. Outdoor junction boxes shall be epoxy painted.

5.04.04 Junction boxes shall be of two types viz. one suitable for control wiring and the other with terminals for power cable terminations. Junction boxes for power cable terminations shall have minimum nine (9) nos. of terminals. Size of terminals shall be suitable to accommodate cables of sizes as required.


5.04.05 **The junction boxes shall have the following indelible markings :**

- Circuit nos. on top by white-stenciled paint at site.
- Circuit nos. with ferrules (inside) as per approved drawing.
- Danger sign in case of 415 V circuit.

5.04.06 Junction boxes shall be provided with two (2) nos. earthing terminals complete with nuts and washers suitable for connection to 8 SWG G.I. wire.

5.05.00 **Terminals**

5.05.01 Multiway terminal blocks of approved type, complete with screws, nuts; washers and marking strips shall be furnished for connection of incoming/outgoing wires.

	Odisha Power Generation Corporation Ltd.	Technical Specification for cable reroute, grounding and lighting protection	IB TPS – 2 X 660 MW Units 3 & 4, Jharsuguda, Odisha
---	--	--	---

5.05.02 Each control cable terminal shall be suitable for connection of 2 nos. 2.5 sq.mm. stranded copper conductors without any damage to the conductor or looseness of conductors.

5.06.00 **Cable Termination & Jointing Kits**

5.06.01 The Seller shall supply cable termination and jointing kits in requisite quantity for H.V. Power Cables, L.V. Power, Control Cables, Instrumentation Cables, etc. along with all accessories & consumables required for making termination and joints complete. All the materials and components of the termination/joints shall be suitable and compatible with the type of cables for which the terminals/joints are intended.

5.06.02 The straight through joints of H.V. and L.V. cables shall be of Tapex /Paracast /Parawrap type. The end termination kits for H.V. cables shall be of Raychem/3M/Elastimold type. Cable joint or end terminations on Electrical equipment shall be suitable for Indoor & Outdoor use, as the case may be.

5.06.03 Glands and lugs required for termination of H.V., L.V. and instrumentation cables shall be supplied by the Seller in required quantity.

5.07.00 **Cable Glands**

Cable glands shall be tinned brass gland, double compression type complete with necessary armour clamp and tapered washer etc. Cable glands shall match with the sizes of different H.V./L.V./Control cables.

5.08.00 **Cable Lugs**

All cable lugs shall be Cd plated copper. Cable lugs shall be suitable for termination of different cross-sections of H.V./L.V./Control/Instrumentation cables and shall be of following types :

- i) Aluminium tubular terminal end for solderless crimping to aluminium conductors.
- ii) Copper tubular terminal end for solderless crimping to copper conductors.


Solderless crimping of terminals shall be done by using corrosion inhibiting compound. The cable lugs shall suit the type of terminals provided on the equipment. Lugs for control/instrumentation cables shall be PVC insulated/sleeved type.

- iii) Cable lugs for control cable termination shall be insulated. These lugs shall be pin type/flat type/ring type/U type to suit the terminals provided in the panels.

5.09.00 **Consumables and Hardware**


5.09.01 The Seller shall furnish all erection materials, hardware and consumables required to complete the installation.

		Mantra Udyog
--	--	--------------

	Odisha Power Generation Corporation Ltd.	Technical Specification for cable reroute, grounding and lighting protection	IB TPS – 2 X 660 MW Units 3 & 4, Jharsuguda, Odisha
--	--	--	---

- 5.09.02 The materials shall include but not be limited to the following :
- Consumables : Oil and grease, cleaning fluids, paints, electrical tape, soldering materials etc.
- Hardware : Bolts, nuts, washers, screws, brackets, supports, clamps, hangers, saddles, cleats, sills, shims etc.
- 5.09.03 Supply of cement, sand, stone etc. required for the execution of the contract shall be the responsibility of the Seller.
- 5.10.00 **Testing Equipment**
- 5.10.01 The major testing equipment that are required to be provided by the Seller are listed below:
- a) Contact resistance measuring set for micro-ohms.
- b) Torque wrench of various sizes.
- 5.10.02 The list of materials is indicative only. Any other special type of material required for Erection work shall be arranged by the Seller.
- 6.00.00 **METHODS AND WORKMANSHIP**
- 6.01.00 All work shall be installed in a first class, neat workmanlike manner by mechanics/electricians skilled in the trade involved.
- 6.02.00 All details on installation shall be electrically and mechanically correct.
- 6.03.00 The installation shall be carried out in such a manner as to preserve access to other equipment installed.
- 7.00.00 **INSTALLATION**
- The equipment and system supplied by Seller shall be installed by erection contractor appointed by Buyer. The Technical Advisory Personnel of Seller shall be responsible for inspection of all critical erection works.
- The Seller shall review the installation requirements mentioned below and incorporate necessary requirements in the design
- 7.01.01 Installation work shall be carried out in accordance with good engineering practices and also as per manufacturer's instructions/ recommendations where the same are available.
- 7.01.02 Equipment shall be installed in a neat workmanlike manner so that it is level, plumb, square and properly aligned and oriented.
- 7.01.03 Cable installation work shall mean erection of cable trays/racks, supports, hangers, junction boxes, conduits, laying of cables either in ground or on trays inside trenches tunnels/overhead trays in conduits etc. dressing and clamping, jointing and termination inclusive of supply of necessary jointing/termination

		Mantra Udyog
--	--	--------------

	Odisha Power Generation Corporation Ltd.	Technical Specification for cable reroute, grounding and lighting protection	IB TPS – 2 X 660 MW Units 3 & 4, Jharsuguda, Odisha
--	--	--	---

kits, lugs, glands, ferrules, tapes etc. and other accessories, grounding of cable armour. In case of direct laying in ground, all excavation work, necessary back-filling, supply of bricks and protective concrete slabs, removal of excess earth shall be part of the installation work.

7.01.04 Grounding installation work shall mean erection, jointing/ brazing/welding, connection and painting, testing of ground conductors including supply of necessary steel/copper.

7.01.05 Lightning protection system installation work shall mean erection, jointing, welding, connection and painting, testing of air termination network, down conductors, shielding masts, connection to ground grid, electrodes, risers, horizontal conductors etc. of lightning protection system.

7.02.00 **Cable Trays**

7.02.01 Pre-fabricated cable trays and accessories shall be assembled & erected at site. Adequate spaces shall be provided to facilitate installation of cable system and to allow routine inspection and modification after installation.

7.02.02 Cable trays either inside concrete trenches or inside buildings and racks inside cable shafts shall be aligned and leveled properly. All tray runs shall be installed parallel to the trench/building walls and floors except otherwise noted in the approved drawings.

7.02.03 As far as practicable, cable trays shall be supported from one side only in order to facilitate installation and maintenance of cables from the other side.

7.02.04 The cable trays shall be supported in general at a span of exceeding 1.25 metres horizontally and 1.0 metre vertically.

7.02.05 Sufficient spacing not less than 250 mm shall be provided between trays and maintained to permit adequate access, for installing and maintaining the cables.


7.02.06 Cable tray support shall be C1/C2 channel type.

7.02.07 Complete cable tray support structure after installation shall be inspected/tested for welding strength, straightness, accuracy, use of proper sizes and compliance to drawings.

7.02.08 Complete cable tray and accessory installation work shall be inspected/tested for proper alignment, leveling, use of proper accessories, high quality workmanship etc.


7.02.09 The Seller shall remove the RCC/steel trench covers whenever required and shall again place the same in their positions after the erection work in the particular area is completed or when further work is not likely to be taken up for some time.

7.02.10 Whenever any pipe/conduit/cable tray emerges out or enters into a building care should be taken to ensure that no water enters into the building.

	Odisha Power Generation Corporation Ltd.	Technical Specification for cable reroute, grounding and lighting protection	IB TPS – 2 X 660 MW Units 3 & 4, Jharsuguda, Odisha
--	--	--	---


- 7.02.11 Cable trays in areas subject to excessive coal dust, oil spillage, mechanical damage or accessible to personal contact shall be provided with raised sheet metal tray covers, installed on upper tray in horizontal run and front in vertical run.
- 7.02.12 Cable trays/racks shall be so arranged that they do not obstruct or impair clearances of passage way.
- 7.02.13 Cable tray/conduit system shall be so designed as to accommodate maximum pulling tension and minimum bending radius of cable.
- 7.02.14 Cable tray/conduit system shall be constructed to prevent drainage of water into equipment or building.
- 7.02.15 Cable tray/conduit system shall be electrically continuous and grounded.
- 7.02.16 Different voltage grade cables shall be laid in separate trays when trays are run in tier formation. Power cables shall normally be on top trays and control/instrumentation cable on bottom trays.
- 7.03.00 **Cable and Conduits**
- 7.03.01 The Seller shall install, terminate and connect up all cable and conduits as per drawings and cable schedules.
- 7.03.02 The drawings shall be strictly followed except where obvious interference occurs. In such cases, the routing shall be changed as directed and/or approved by the Engineer.
- 7.03.03 Approximate lengths of cable and conduit runs shall be shown by the Seller in the cable schedule for guidance only. Before commencement of work the Seller shall take actual measurements and prepare his own cable-cutting schedule to reduce wastage to a minimum.
- 7.03.04 The Seller shall also maintain and submit when requested, a record of cable insulation value when drawn from store, after laying, before and after termination/jointing.
- 7.03.05 Where direct heat radiation exists, heat isolating barriers, shall be adopted for cabling system.
- 7.03.06 Cabling/wiring in offices, laboratories, control rooms etc. shall be taken through concealed G.I. or rigid PVC pipes as directed by the Buyers Nominee.
- 7.03.07 At certain places where hazardous fumes/gasses may cause fire to the cables, cable trenches after installation of cables shall be sand filled.
- 7.04.00 **Conduit and Accessories**
- 7.04.01 Conduit/pipes shall be used only in short lengths in certain areas where required and/or as directed by the Engineer.
- 7.04.02 The Seller shall furnish all conduits complete with accessories as required.

		Mantra Udyog
--	--	--------------

	Odisha Power Generation Corporation Ltd.	Technical Specification for cable reroute, grounding and lighting protection	IB TPS – 2 X 660 MW Units 3 & 4, Jharsuguda, Odisha
--	--	--	---

- 7.04.03 Conduits shall be flexible type in general. However, rigid type steel conduit if required shall also be supplied by the Seller.
- 7.04.04 Except for inside an enclosure wherever the cable enters or leaves the conduit, the conduit end shall be sealed by suitable sealing compound, having fire withstand capability.
- 7.04.05 The entire metallic conduit system, when embedded or exposed shall be electrically continuous and grounded.
- 7.04.06 Where it is possible for water or other liquids to enter conduits, sloping of conduit runs and drainage of flow points shall be considered.
- 7.04.07 Pull boxes shall be installed between termination points where required to facilitate cable pulling, but at a maximum interval of 30 meters.
- 7.04.08 Conduits shall be firmly fastened within 900 mm of each junction box/pull box/cabinet/fitting etc. Conduits shall be supported at least every 2000 mm.
- 7.05.00 **Cables: Storage and Handling**
- 7.05.01 Cable drums shall be stored on hard and well-drained surface so that they may not sink. In no case shall the drum be stored on the flat, i.e., with flange horizontal.
- 7.05.02 Rolling of drums shall be avoided as far as practicable, for short distance, the drums may be rolled provided they are rolled slowly and in proper direction as marked on the drum.
- 7.05.03 In absence of any indication, the drums may be rolled in the same direction as it was rolled during taking up the cable.
- 7.05.04 For unreeling the cable, the drum shall be mounted on jacks or on cable wheel. The spindle shall be strong enough to carry the weight without bending.
- 7.05.05 The drum shall be rolled on the spindle slowly so that the cable should come out over the drum and not below the drum.
- 7.05.06 While laying cable, cable rollers shall be used at an interval of 2000 mm. The cables shall be pushed over the roller by a gang of people positioned in between rollers over a suitable distance. Care shall be taken so that kinks and twists or any mechanical damage does not occur in cables. Only approved cable pulling grips or other devices shall be used. Cables shall not be dragged on ground or along structure while laying out from cable drums.
- 7.05.07 Cable shall not be pulled from the end without having intermediate pushing arrangement. Bending radius of the cable during installation shall not be less than what is specified by the manufacturer.
- 7.05.08 Empty cable drums shall be returned to the Buyer.
- 7.06.00 **Cable Laying**

		Mantra Udyog
--	--	--------------

	Odisha Power Generation Corporation Ltd.	Technical Specification for cable reroute, grounding and lighting protection	IB TPS – 2 X 660 MW Units 3 & 4, Jharsuguda, Odisha
--	--	--	---

7.06.01 Cable shall generally be installed in ladder type prefabricated trays except for some short run in rigid/flexible conduit for protection or crossings.

7.06.02 Cables laid on trays and risers shall be neatly dressed and clamped with self-locking type fire resistant nylon ties at an interval of 750 mm for horizontal and vertical runs, in case of both power, control and instrumentation cables.

7.06.03 All single core power cables for 3 Ph. AC circuits shall be laid in trefoil formation and suitably clamped with self-locking type fire resistant nylon ties at an interval of 750 mm.

7.06.04 All H.V. multicore power cables and L.V. multicore power cables with cross-sectional area including & above 95 sq.mm shall be clamped individually by self-locking type fire resistant nylon ties.

7.06.05 L.V. power cables of cross sectional area less than 95 sq. mm. and all control and Instrumentation cables shall be clamped in bunches with self-locking type fire resistant nylon ties. The number of cable in one bunch shall not exceed eight (8).

7.06.06 Prior to laying of cables inside the indoor and outdoor trenches, the Seller shall properly clean the trenches.

7.06.07 In outdoor areas, buried cables shall be laid and covered with sand/riddled earth and protected from damage by bricks at sides and precast slab at top.

7.06.08 When buried cables cross road/railway track, adequate protection shall be provided in the form of hume/ galvanised iron pipes laid at a minimum depth of 1 meter below ground.

7.06.09 After completion of installation and prior to connection, all power cables shall be subjected to a high potential test.

7.07.00 **Cable Tags & Markers**

7.07.01 Each cable and conduit run shall be tagged with numbers that appear in the cable and conduit schedules. Cables and conduits shall be tagged at their entrance, bends, every 30.0M and exit from any equipment, junction box. When a cable/conduit passes through a wall, tags shall be fitted on both sides of the wall.

7.07.02 The tags shall be of aluminium with the number punched on it and securely attached to the cable by not less than two turns of 16 SWG G.I. wire. For single core cable the wire shall be of non-magnetic material.


7.07.03 The location of cable joints, if any, shall be clearly indicated with cable marker with an additional inscription 'cable-joint'.

7.07.04 The Seller shall furnish and install all tags and markers stated above.


7.07.05 For buried cable, the marker shall project 150 mm above ground and shall be spaced at an interval of 30 meters and at every change of direction.

7.08.00 **Cable Termination and Connection**

		Mantra Udyog
--	--	--------------

	Odisha Power Generation Corporation Ltd.	Technical Specification for cable reroute, grounding and lighting protection	IB TPS – 2 X 660 MW Units 3 & 4, Jharsuguda, Odisha
---	--	--	---

- 7.08.01 The termination and connection of cables shall be done strictly in accordance with manufacturer's instruction, drawings and/or as directed by the Engineer.
- 7.08.02 The work shall include all clamping, fitting, fixing, soldering, tapping, compound filling, cable jointing, crimping, shorting and grounding as required for the complete job. All equipment required for all such operations shall be of Seller's procurement.
- 7.08.03 Furnishing of all consumable materials such as soldering material, electrical tape, sealing material as well as cable jointing kits shall be included.
- 7.08.04 Cable joint kits for all cables shall be supplied by Seller under this specification. Responsibility for proper termination shall lie on the Seller. Guarantee for termination shall also have to be given by Seller.
- 7.08.05 The equipment shall be generally provided with blank bottom plates for cable/conduit entry and cable end box for power cables.
- 7.08.06 The Seller shall perform all drilling, cutting on the blank plate and any minor modification work required to complete the job.
- 7.08.07 If the cable end box or terminal enclosure provided on the equipment is found unsuitable and requires major modification, the same shall be carried out by the Seller.
- 7.08.08 Control/instrumentation cable cores entering control panel/ switchgear/MCC etc. shall be neatly bunched and served with PVC perforated tape to keep it in position at the terminal block.
- 7.08.09 The Seller shall put ferrules on all control cable cores in all junction boxes and at all terminations. The ferrules shall carry terminal numbers as per drawings. All ferrules shall be coloured, plastic & interlocked type.
- 7.08.10 Spare cores shall be similarly ferruled, crimped with lug and taped on the ends. Spare cores shall be ferruled with individual cable number.
- 7.08.11 Termination and connection shall be carried out in such a manner as to avoid strain on the terminals.
- 7.08.12 All cable entry Points shall be properly sealed and made vermin and dust proof. Unusual opening, if any, shall be effectively closed. Sealing work shall be carried out with approved sealing compound having fire withstand capability for at least three hours.
- 7.09.00 **Termi-point Connection**
- a) The conductor (solid or stranded) is forced against the contact area of the 2.4 x 0.8 mm or 1.6 x 0.8 mm connection pin by means of a tin-coated bronze clip, which maintains a constant pressure. In the Maxitermi-point method, 2.4 x 0.8 mm pins is used without exception.

	Odisha Power Generation Corporation Ltd.	Technical Specification for cable reroute, grounding and lighting protection	IB TPS – 2 X 660 MW Units 3 & 4, Jharsuguda, Odisha
--	--	--	---

- b) The conductor is "shot" onto the pin together with the clip. The resulting friction causes both the wire and the contact area of the pin to be cleaned and any oxide layers to be penetrated.
- c) Apart from this the wire and the clip are deformed in such a way that a gas-tight connection with very good electrical and mechanical properties is established.
- d) A special manually or pneumatically driven gun is required. Up to 3 adjacent connections can be "shot" onto one pin. In most cases only one clip at the base of the pin is attached. The sections above usually remain vacant. Any part of a connection pin may be reused several times after removal of the existing clip connection. Contact areas below existing connections that have become vacant can be reused by pushing the connections above the vacant space downwards, so that the new connection can be "shot" on above the top connection. The single jumper wires need not be specially prepared as the end insulation is stripped within the tool.
- e) This connection method requires special insulation of the wires. The diameter of solid conductors is 0.8 mm the cross-section of stranded conductors 0.5 Sq.mm.
- f) The conductor is deformed greatly when attached and is to be shortened by 3 mm when disconnected and reused.
- g) Strips and special tools for termi-point connection shall be supplied by the Seller.

7.10.00 **Cable Joints**

7.10.01 Cable shall be installed without joints as far as practicable.

7.10.02 If, however jointing becomes necessary, it shall be made only by qualified cable joiner and strictly in accordance with manufacturer's recommendation.


7.11.00 **Grounding**

7.11.01 The grounding work shall be carried out as per provisions of I.E. rules 1956 Indian standards and enclosed grounding and lightning protection notes and details. Proper interconnections shall be made among various peripheral earthing grids/mats, steel structures, lightning protection system as well as grounding of all electrical equipment, etc.

7.11.02 The grounding shall be done by conductors of sizes as laid down in grounding drawings and the same shall be connected to the risers of main ground mat.


7.11.03 For fabricated cable trays, a separate ground conductor (50x6 mm G.S. flat) shall run along the entire length of each route of cable tray being suitably clamped on the cable tray. Individual cable trays of each section shall be connected to above ground conductor through 50x6 mm G.S. flat to maintain continuity of ground path.

		Mantra Udyog
--	--	--------------

	Odisha Power Generation Corporation Ltd.	Technical Specification for cable reroute, grounding and lighting protection	IB TPS – 2 X 660 MW Units 3 & 4, Jharsuguda, Odisha
--	--	--	---

- 7.11.04 All ground conductor connections shall be made by electric arc welding/brazing unless otherwise specified. Ground connections shall be made from nearest available station ground grid risers.
- 7.11.05 All ground conductors shall be painted black for easy identification.
- 7.11.06 Equipment ground connections, after being checked and tested by the Engineer, shall be coated with anti-corrosive paint.
- 7.11.07 Whether specifically shown or not, all conduits, trays, cable armour and cable end box, electrical equipment such as motors, switchboards, panels, cabinets, junction boxes, lockout switches, fittings, fixtures, etc. shall be effectively grounded.
- 7.11.08 If there is no provision to ground the L.V. transformer neutral at transformer end, to make an effectively earthed 415V system the neutral bus of all 415V distribution boards shall be connected to ground grid at two different and distinct points.
- 7.11.09 The underground mat shall be made of mild steel rods laid underground in length and breadth of the area at a depth shown in drawing but not less than 1 metre below grade level. All crossings and straight run shall be arc welded for good electrical continuity. Ground conductors, when crossing underground trenches, directly laid underground pipe and equipment foundation, if any, shall be at least 300 mm below the bottom elevation of such trenches/pipes as shown in the relevant drawing.
- The Seller shall plan and organise works to lay the grounding mat in the same sequence in which the building and equipment foundation is being done.
- 7.11.10 **Ground Electrode**
- Ground electrodes shall be 40 mm dia and 3 metre long M.S. rod. These are to be fabricated and driven into the ground by the side of mat conductor. All connections to the conductors shall be done by arc welding process.
- 7.11.11 **Risers**
- Risers are required for connecting the equipment and structures with the ground mat. These shall be 1 No. 40 mm dia M.S. rod laid from ground mat to above ground level properly clamped or supported along the outer edge of the concrete foundation. Connection to the ground mat shall be done by arc welding and the other end is to be kept free at least 300 mm above grade level/concrete floor level unless otherwise shown.
- 7.11.12 **Column Grounding**
- All columns are required to be grounded by 1 no. 40 mm dia M.S. rod from ground mat. Laying, supporting along with foundation, connecting at ground mat are within the scope of this specification. At least 300 mm length of the above rods shall be left free above the grade level/concrete floor level for connection with columns.
- 7.12.00 **Painting**

		Mantra Udyog
--	--	--------------

	Odisha Power Generation Corporation Ltd.	Technical Specification for cable reroute, grounding and lighting protection	IB TPS – 2 X 660 MW Units 3 & 4, Jharsuguda, Odisha
--	--	--	---

7.12.01 All steel fabrications at site shall be painted at site with two (2) coats of red oxide primer and two (2) coats of battleship grey (shade no. 632 of IS:5 or equivalent RAL) synthetic enamel paint.

7.13.00 **Galvanising**

7.13.01 The galvanising shall be uniform, clean, smooth, continuous and free from acid spots. Should the galvanising of the samples be found defective, the entire batch of steel has to be regalvanised, at Seller's cost. The amount of zinc deposit shall not be less than 610 grams per square metre of surface area and in addition, the thickness of the zinc deposit at any spot whatsoever shall not be less than 75 microns. The Buyer reserves the right to measure the thickness of zinc deposit by Elkometer or any other instrument and reject any component which shows thickness of zinc at any location less than 75 microns.

7.14.00 **Excavation and Back Filling**

7.14.01 Excavation shall be performed up to the required depth. Such sheeting and shoring shall be done as may be necessary for protection of the work.

7.14.02 The Seller shall make use of his own arrangements for pumping out any water that may be accumulated in the excavation.

7.14.03 All excavation shall be backfilled to the original level with good consolidation.

7.15.00 **Steel Fabrication**

7.15.01 Steel for fabrication shall be straightened and cleaned of rust and grease. All fabrication shall be free of sharp edge and burns so as not to cause any damage to personnel or cables.

8.00.00 **TESTS**

8.01.00 **Shop Tests**

8.01.01 All equipment shall be completely assembled, wired, adjusted and routine tested as per relevant Indian Standards at manufacturer's works.


8.01.02 Tests on panels/junction boxes shall include :

- a) Wiring continuity tests.
- b) High voltage and insulation tests.
- c) Operational tests.

8.02.00 **Site Tests**


The equipment and system supplied by Seller as above shall be installed and tested by erection contractor appointed by Buyer. The Technical Advisory Personnel of Seller shall be responsible for inspection of all critical tests and certify completion.

		Mantra Udyog
--	--	--------------

	Odisha Power Generation Corporation Ltd.	Technical Specification for cable reroute, grounding and lighting protection	IB TPS – 2 X 660 MW Units 3 & 4, Jharsuguda, Odisha
--	--	--	---

- 8.02.01 Cable cores shall be tested for :
- a) Physical damage
 - b) Continuity
 - c) Correctness of connections as per relevant wiring diagram
 - d) Insulation resistance to earth
 - e) Insulation resistance between conductors
 - f) Proper earth connections of cable glands, cable boxes, cable armour, screens etc.
- 8.02.02 All equipment shall be demonstrated to operate in accordance with the requirements of this specification.
- 8.03.00 **Test Certificates**
- 8.03.01 Type test certificate on any equipment, if so desired by the Buyer, shall be furnished. Otherwise the equipment shall have to be type tested, free of charge, to prove the design.
- 9.00.00 **DRAWINGS, DATA & MANUALS**
- 9.01.00 NOT USED.
- 9.02.00 **To be submitted after Award of Contract**
- 9.02.01 Make, type and catalogue number of cable termination kits, joints and accessories.
- 9.02.02 Detail dimensional drawings showing constructional features, grounding, fixing arrangement etc.
- 9.02.03 Bill of Materials for Pre-fabricated cable tray and accessories, Conduits, accessories & all other items required for complete installation.
- 9.02.04 Dimensional G.A. drawings and data sheets for all equipment and items supplied under this specification.
- 9.02.05 Layout drawing of Grounding system and Lightning protection system showing connection details along with backup design calculation and detailed write up.
- 9.02.06 Bill of material for entire grounding system and lightning protection system.
- 9.02.07 Drawing showing details of equipment grounding system.
- 9.02.08 Field Testing procedures and acceptance limits

		Mantra Udyog
--	--	--------------

	Odisha Power Generation Corporation Ltd.	Technical Specification for Workshop Package	IB TPS – 2 X 660 MW Units 3 & 4, Jharsuguda, Odisha
---	--	--	---

ANNEXURE-A

NOTES AND DETAILS FOR CABLING SYSTEM

1.00.00 GENERAL

1.01.00 These notes and details shall be read and construed in conjunction with Specification and the drawings meant for cable tray details and supporting arrangements in Trench, Racks etc., enclosed elsewhere. In case of conflict between these notes and drawings, the latter shall prevail.

1.02.00 The Cabling System installation work shall conform to the requirements of the latest revisions of the following standards/codes

- a) Indian Electricity Rules, 1956, with up to date amendment.
- b) I.S. Code of Practice for cable installation

2.00.00 CABLE ROUTING/LAYING

2.01.01 Cables shall generally be laid on ladder type cable trays either in trenches or overhead supported from building steel/structures except in some cases cables may have to be laid underground and for short runs in conduits for protection or crossing.

2.01.02 For interplant connections, the cables may be directly buried or shall be routed through an overhead cable bridge or cable trenches/tunnels selection being dependent on site constraints.

2.01.03 For underground crossing of railways, roads etc. hume pipes shall be used and shall be laid at a depth of minimum 1000 mm such that cables shall not be damaged.

2.01.04 In boiler area, trench shall be avoided as far as practicable. The cable racks shall be supported from Boiler structure in vertical configuration with suitable cover to avoid deposition of coal dust as far as practicable.

2.01.05 Different voltage grade cables shall be laid in separate trays when trays are arranged in tiers. Power cables shall be on top trays and Control/Instrumentation cables on bottom trays, and it is recommended that trays for cables of different voltage levels be stacked in descending order with higher voltage level above.

2.01.06 Cables for redundant equipment/system shall be run in separate trays in separate route.

2.01.07 Cables from two different services viz. supply from station board and supply from unit board shall be fully segregated to prevent simultaneous damage due to fire in one of the services.

		MANTRA UDYOG.
--	--	---------------

	Odisha Power Generation Corporation Ltd.	Technical Specification for Workshop Package	IB TPS – 2 X 660 MW Units 3 & 4, Jharsuguda, Odisha
--	--	--	---

ANNEXURE-A

- 2.01.08 Low level signal cables and other special Instrumentation and Control cables shall run in separate trays. In general, a minimum of 1500 mm clearance shall be maintained between these cables and noise generating equipment (large motors, generators, transformers etc.).
- 2.01.09 The cable spreaders of each unit shall be compartmentalized by provision of fire proof partition wall.
- 2.01.10 The floor of the cable spreader rooms shall have to be made water proof so that water does not percolate to lower levels in the event of fire fighting operations. Adequate arrangement for efficient drainage of water shall be provided. The cable raceways should also be suitably curved to avoid water entry through this place.
- 2.02.00 **Cable Trays/Supports**
- 2.02.01 Cable trays and covers shall be pre-fabricated type, constructed from minimum 14 SWG sheet steel for trays and 16 SWG for covers and hot-dip galvanized after fabrication.
- 2.02.02 Cable tray supports shall be cantilever type for each installation. All supports and hardware shall be hot-dip galvanised. Support shall be fixed with bolts and no welding shall be done on the galvanized parts.
- 2.02.03 Standard cable tray width shall be 600 mm. However, trays with 450, and 300, 150 mm width may be used in some places considering the requirement and space restrictions. For instrumentation and control purpose, some perforated type cable trays of width 150 and/or 100mm may be used particularly in Boiler Platform area, and 600, 450, 300 mm perforated trays may be used depending on site requirement.
- 2.02.04 Cable trays shall be ladder type with 250 mm rung spacing, 100 mm depth and rung width not less than 50 mm.
- 2.02.05 All weld for cable tray supports shall have a minimum throat thickness of 6 mm.
- 2.02.06 Cable trays in areas subjected to excessive coal dust, or mechanical damage shall have hot-dip galvanised sheet metal tray cover installed on front tray in vertical run and inverted 'V' type on upper tray in horizontal run.

Where covers are used on trays containing power cables, consideration should be given to ventilation requirements. Areas where corrosive chemicals are likely to be handled, cable tray and covers shall be epoxy painted.
- 2.03.00 **Conduits**
- 2.03.01 Conduits shall be rigid steel coated type; minimum size of conduit shall be limited to 19mm.
- 2.03.02 Steel conduits with interior coating of silicon epoxy ester for ease of wire pulling shall be seamed by welding and flo-coat metal conduit/hot-dip galvanised. These shall be supplied in standard length of 5M with minimum wall thickness as specified in IS: 9537 Part-II. In chemical handling areas, Battery room etc.,

		MANTRA UDYOG.
--	--	---------------

	Odisha Power Generation Corporation Ltd.	Technical Specification for Workshop Package	IB TPS – 2 X 660 MW Units 3 & 4, Jharsuguda, Odisha
---	--	--	---

ANNEXURE-A

the exterior surface shall be further coated with chromate and polymer for better resistance to corrosion.

2.03.03 Conduit runs shall be supported at an interval of 750 mm for vertical run and 1000 mm for horizontal run.

2.03.04 Conduits shall be sized so that conduit fill (ratio of total cable area to conduit area) shall not exceed the following :

One Cable	:	53%
Two Cable	:	31%
Three Cables & Up	:	40%

2.03.05 Conduit runs shall be provided with necessary bends as required.

2.04.00 **Installation**

2.04.01 The Seller shall install, terminate and connect up all cables and conduits with supporting arrangements as per drawings, cable schedules and interconnection chart/drawings.

2.04.02 The HV power cables of 11 KV/3.3 KV shall be laid in trays or racks as follows :

- a) In single layer only.
- b) 3 core cables to be laid giving one diameter gap of the largest diameter adjacent cable.
- c) Single core cables to be laid in trefoil formation with a spacing equal to diameter of the trefoils.

2.04.03 1100V grade power cables shall be laid in single layer in trays.

2.04.04 1100V grade power cable shall be laid giving one diameter gap of the largest diameter adjacent cable.

2.04.05 Control and Instrumentation cables can be laid up to a maximum of three layers in each tray.

2.04.06 The trays shall be run with a vertical spacing of 300 mm for overhead cable trays as well as inside cable trenches. A minimum of 225 mm clearance shall be provided between the top of tray and beams, cold piping, 500 mm clearance for hot piping/object to facilitate installation of cables in tray.

2.04.07 Adequate pull boxes shall be provided in conduit run to facilitate cable pulling in long runs and also to ensure that there shall be no more than 270 Deg. bends between pull points.

2.04.08 Cable tray/conduit system shall be installed to accommodate cable manufacturer's recommended maximum pulling tension and minimum bending radius.

- 2.04.09 All openings in the floor and wall for cable access shall be sealed after installation of the cable system with non-inflammable materials, as follows :
- i) Fire stop/Penetration seal shall be installed in the cable spreaders and cable raceways.
 - ii) Similarly in the trenches fire stop/penetration seals shall be provided at suitable interval to avoid spread of fire.
 - iii) For all H.V., L.V., Relay and Control panels, Control desk, instrumentation panels, battery charger, D.C. Dist. boards and other miscellaneous panels, fire-stops should be provided below base plate.
- 2.04.10 All floor/wall openings for cable entry to the electrical equipment and accessories shall be sealed with non-inflammable materials, after completion of cable installation. Thickness of such materials shall be equal to the thickness of floor/wall unless specified otherwise.
- 2.04.11 The portion of galvanised steel, which, if required, undergoes any welding at site shall be coated with two (2) coats of cold galvanising anti-corrosive paint after welding.
- 2.04.12 The cables shall be coated with fire protection coating as specified elsewhere.
- 2.05.00 **Identification**
- 2.05.01 The complete cabling system shall be properly identified. Methods for identification of cabling system shall be furnished to the Seller and the Seller shall strictly adhere to the said methods.
- 2.05.02 Each cable and conduit run shall be tagged with numbers that appear in the cable and conduit schedule.
- 2.05.03 Location of cables laid directly underground shall be clearly indicated with cable marker made of galvanised iron plate, projected above ground level.
- 2.05.04 Cable tags shall be provided on all cables at each end (just before entering the equipment enclosure), on both sides of a wall or floor crossing, on each duct/conduit entry, at each bend and at every thirty (30) metres in cable tray/trench runs. Cable tags shall also be provided inside the switchgear, MCC, control & relay panels etc. wherever required for cable identification, such as where a number of cables enter together through a gland plate.

CABLE WORK

sl no	Cable size	No of Cable	length of each cable	total length of cable	UOM
1	12C x 2.5	6	300	1800	Mtr
2	3C x 6	6	300	1800	Mtr
3	3.5C x 400	2	300	600	Mtr
4	3.5C x 150	1	300	300	Mtr

	Odisha Power Generation Corporation Ltd.	Technical Specification for Workshop Package	IB TPS – 2 X 660 MW Units 3 & 4, Jharsuguda, Odisha
---	--	--	---

ANNEXURE-A

5	7C x 2.5	2	300	600	Mtr
6	3.5C x 35	3	300	900	Mtr
7	3.5C x 35	1	100	100	Mtr
8	2C x 16	1	300	300	Mtr
9	4C x 6	1	300	300	Mtr
10	3C x 240 (6.6kv)	6	200	1200	Mtr
11	3C x 300 (6.6kv)	2	100	200	Mtr
12	Cable Tray		250	250	Mtr
13	(6.6 KV) cable joint	8	1	8	job

	Odisha Power Generation Corporation Ltd.	Technical Specification for Workshop Package	IB TPS – 2 X 660 MW Units 3 & 4, Jharsuguda, Odisha
---	--	--	---

ANNEXURE-B

NOTES & DETAILS FOR GROUNDING & LIGHTNING PROTECTION

1.00.00 GENERAL

1.01.00 These notes and details shall be read and construed in conjunction with grounding and lightning protection drawings and specification. In case of conflict between these notes and drawings, the latter shall prevail.

1.02.00 The grounding and lightning protection system installation work shall conform to the requirements of the latest editions of the following standards/codes :

- a) Indian Electricity Rules, 1956.
- b) National Electrical Code, 1985.
- c) Code of Practice for Earthing (IS: 3043)
- d) Protection of Buildings and Allied Structures Against Lightning (IS: 2309)
- e) IEEE 80

2.00.00 GROUNDING SYSTEM

2.01.00 Main Grounding Mat/Grid

2.01.01 The main ground grid shall be buried in earth at a minimum depth of 1000 mm below finished grade level unless stated otherwise. The size of ground grid conductor shall be bare 40 mm dia. mild steel rod.

2.01.02 A minimum earth coverage of 300 mm shall be provided between the ground grid conductor and the bottom of trenches, tunnels, underground pipes, foundations, railway tracks etc. The ground grid conductor shall be re-routed in case it fouls with equipment foundations.

2.01.03 In some cases, it may happen that the construction work of cable trench, foundation and laying of underground pipes are being taken up after the grounding mat has been laid. It may be required to cut a portion of grounding conductor to avoid fouling with cable trench, equipment foundations, underground pipes etc. In this case, the ground conductor shall be properly rerouted and rejoined/reconnected with the main grounding mat during the construction/laying of above underground objects and good electrical continuity of grounding conductor shall be ensured.

2.01.04 Grounding conductors crossing the road may have to be laid at greater depth to suit the site conditions.

2.01.05 Grounding conductor around the building shall be buried in earth at a minimum distance of 1200 mm from the outer boundary of the building.


		Mantra Udyog
--	--	--------------

	Odisha Power Generation Corporation Ltd.	Technical Specification for Workshop Package	IB TPS – 2 X 660 MW Units 3 & 4, Jharsuguda, Odisha
--	--	--	---

ANNEXURE-B

- 2.02.00 **Grounding Electrodes**
- 2.02.01 The ground electrodes shall be 40 mm dia, 3000 mm long mild steel rod. These shall be fabricated and driven into the ground by the side of grounding mat conductors and connected to the ground mat conductors.
- 2.03.00 **Risers**
- 2.03.01 All risers/pigtail from the ground grid shall be 40 mm dia mild steel rod and shall be projected 300 mm above grade level/concrete floor level unless otherwise shown.
- 2.04.00 **Earthing Conductor**
- 2.04.01 75 x 10 mm galvanised steel flats shall be run as main earthing conductors above ground along building columns, walls, steel structure, etc. for equipment and other structures earthing.
- 2.04.02 These earthing conductors shall be interconnected between them and to the main ground grid through risers/pigtail. The connection between earthing conductor and riser shall be made above ground.
- 2.04.03 Earthing conductors along their run on column, wall etc. shall be supported by suitable welding/clamping at intervals set exceeding 750 mm.
- 2.04.04 Earthing conductors shall be embedded in concrete floor of the building without having direct contact with the reinforcement rods.
- 2.04.05 At the crossing of building walls, floors etc. the earthing conductor shall be passed through galvanised conduit sleeves. Both ends of the sleeve shall be sealed to prevent the passage of water through the sleeves.
- 2.05.00 **Grounding of Equipment And Structures**
- 2.05.01 All indoor and outdoor electrical equipment and associated non-current carrying metal works, supporting structures, building/ boiler columns, fence, system neutrals, lightning masts/arresters shall be connected to the plant ground system.
- 2.05.02 Two separate and distinct ground connections shall be provided for grounding electrical equipment frameworks in compliance with I.E. rules.
- 2.05.03 All Electrical equipment shall be furnished with two (2) separate ground pads with tapped holes, bolts and spring washers. The connection between these ground pads and the grounding grid shall be made by short and direct earthing conductors free from kinks and splices.
- 2.05.04 Miscellaneous devices such as junction boxes, pull boxes, pushbutton stations, lockout switches, cable end boxes, lighting fixtures, receptacles, switches etc. shall be effectively grounded whether specifically shown or not.

		Mantra Udyog
--	--	--------------

	Odisha Power Generation Corporation Ltd.	Technical Specification for Workshop Package	IB TPS – 2 X 660 MW Units 3 & 4, Jharsuguda, Odisha
---	--	--	---

ANNEXURE-B

- 2.05.05 The generator neutrals, transformer neutrals, earthing terminals of lightning arresters, coupling capacitor shall be directly connected to rod electrodes through riser which in turn, shall be connected to station grounding mat.
- 2.05.06 Grounding mat comprising closely spaced conductors shall be provided below the operating handles of isolator and circuit breaker operating box located in outdoor high voltage substation. The operating handles shall be properly bonded with flexible conductors.
- 2.05.07 Metallic conduits and pipes shall not be used as earth continuity conductor. These shall be grounded at both ends.
- 2.05.08
- a) The cable trays inside the cable trenches shall be grounded thru' one (1) no. 40 mm dia M.S. Rod at an interval of ten (10) metres. One end of this rod is connected with riser from grounding mat and the other end which is projected inside the cable trench shall be connected with one (1) 50 x 6 mm G.S. flat which runs horizontally along the cable trench. This earthing conductor shall be securely attached to each tray section of cable tray/trays forming a solidly grounded tray system through 50 x 6 mm G.S. flats.
 - b) A continuous 50 x 6 mm G.S. flat earthing conductor shall run along the supporting structure of overhead cable trays/cable shafts. This earthing conductor shall be attached to each section of cable tray/trays through 50 x 6 mm G.S. flats.
- 2.05.09 Fence within the ground grid shall be bonded to the plant ground system at regular interval not exceeding ten (10) metres. Fence gate shall be separately grounded with flexible connection to permit movement.
- 2.05.10 The street lighting poles, junction boxes mounted on the poles, flood light supporting structures etc. shall be connected to ground grid at minimum two points.
- 2.05.11 The steel columns, metallic stairs, hand-rail etc. of the building where electrical equipment are located shall be connected to the nearby ground mat by earthing conductor. Electrical continuity shall be ensured by bonding the different sections of handrails and metallic stairs.
- 2.05.12 The railway tracks within plant area shall be bonded across fish plates and the rail tracks shall be connected to grounding grid at different locations. The rail tracks leaving the plant boundary shall be made electrically discontinuous from the rail tracks inside the plant area by providing suitable arrangements at fish plate joints.
- 2.05.13 The overhead crane rails shall be grounded at both ends. In addition all joints shall be bonded to provide electrical continuity.
- 2.05.14 The flexible earthing connection of jumpering wire shall be provided where flexible conduits are connected to rigid conduits to ensure continuity.

		Mantra Udyog
--	--	--------------

2.06.00 Earthing of Cable

2.06.01 The metallic sheaths, screens and armour of cables shall be earthed at both switchgear/MCC/DB and equipment ends.

2.07.00 Jointing and Connection

2.07.01 All ground conductor connections below ground level shall be done by electric arc welding with low hydrogen content electrode. The contact surfaces shall be thoroughly cleaned to provide good electrical continuity.

2.07.02 The bending of the large diameter ground conductor where necessary shall be done by gas heating.

2.07.03 The projected portion of riser/pigtail above ground shall be coated with two coats of bitumen paints (anti-corrosive paints) with a minimum thickness of 1 mm after connection.

2.07.04 The connections between the riser/pigtail and earthing conductors (galvanised steel flats) and between the earthing conductors above ground level shall be made by electric arc welding.


2.07.05 The portion of galvanised steel flats, which undergoes welding at site, shall be coated with two (2) coats of cold galvanising anti-corrosive paint after welding.

2.07.06 The earthing connections to equipment grounding pads/terminals and some removable structures shall be bolted type with GI bolts and nuts. The contact surfaces shall be thoroughly cleaned (to free from scale, paint, enamel, grease, rust) before connection to ensure good electrical contact.

2.07.07 Equipment/structures ground connections after properly checked and tested shall be coated with weather resistant paints/cold galvanising paints.

2.08.00 The sizes and materials of ground conductors used in grounding system are listed below :

	DESCRIPTION	SIZE	MATERIAL
a)	Main Grounding Grid Conductor	40 mm dia Rod	Mild Steel
b)	Riser/Pigtail From Grounding Grid/Mat	40 mm dia Rod	- Do -
c)	Electrode	40 mm dia Rod 3000 mm long.	- Do -
d)	Conductor used for connection of various equipment/structures as listed below		
i)	11 kV/3.3kV Equipment	75 x 10 mm Flat	Galvanised Steel

	Odisha Power Generation Corporation Ltd.	Technical Specification for Workshop Package	IB TPS – 2 X 660 MW Units 3 & 4, Jharsuguda, Odisha
--	--	--	---

ANNEXURE-B

ii)	Structures, Bus Duct Control Panels, Cable Trays etc.	50 x 6 mm Flat	- Do -
iii)	415V Power Control Centres, Motor Control Centres, Distribution Boards etc.	50 x 6 mm Flat	- Do -
iv)	Local Panels, Lighting Panels	35 x 6 mm Flat	- Do -
v)	Motors :		
	Above 90 kW	50 x 6 mm Flat	- Do -
	Above 30 kW Upto 90 kW	35 x 6 mm Flat	- Do -
	Above 5 kW Upto 30 kW	25 x 3 mm Flat	- Do -
	Upto 5 kW	8 SWG Wire	Galvanised Iron
vi)	Miscellaneous Items, viz. Push Button Station, Junction Boxes etc.	8 SWG Wire	- Do -

3.00.00 LIGHTNING PROTECTION SYSTEM

3.01.00 Air Terminations

3.1.1 The vertical air terminal rods shall be installed at the roof of buildings (including power house main building) to protect from lightning strokes.

3.01.02 The vertical air terminal shall be made of 20 mm dia galvanised steel rod. The projected length of the rod shall be as required to protect the object (on which the rod is fixed) from lightning stroke.

3.01.03 The air terminal rod shall be properly fixed on the top of the building/structure to withstand very high wind pressure. In case the air terminal rod is embedded at the top of roof of building: the portion embedded inside the concrete shall not touch the reinforcement bars and shall be duly insulated from them.

3.01.04 All the vertical air terminal rods shall be electrically connected together by means of horizontal conductors of size 50 x 6 mm galvanised steel flats.

3.01.05 The shielding angle for one vertical air termination shall be 45 degrees. For more than one rod, shielding angle between the rods shall be taken as 60 degrees.

3.01.06 Horizontal air termination (i.e. G.S. Flat conductor) shall be so laid that no part of the rod shall be more than nine (9) metres from the nearest roof conductor.

3.02.00 Shielding Masts

		Mantra Udyog
--	--	--------------

	Odisha Power Generation Corporation Ltd.	Technical Specification for Workshop Package	IB TPS – 2 X 660 MW Units 3 & 4, Jharsuguda, Odisha
---	--	--	---

ANNEXURE-B

- 3.02.01 The shielding mast for lightning protection shall be installed at the top of steel columns cap plates of power house main building.
- 3.02.02 The shielding mast shall be made of galvanised steel pipe and the height of the same shall be decided considering the zones to be protected.
- 3.02.03 Each shielding mast shall be connected to grounding grid by a down conductor 50 x 6 mm. Galvanised steel flat run along the building column. In addition all powerhouse building columns joints shall be electrically bonded.
- 3.03.00 **Down Conductors**
- 3.03.01 The down conductors shall be 50 x 6 mm galvanised steel flats. One end of this shall be connected with air terminal rod/horizontal conductor at the top of roof/structure and other end connected to the nearest 40 mm dia. mild steel rod riser from ground electrode.
- 3.03.02 Each down conductor shall have an independent earth termination. In no case conductors of the lightning protection system shall be connected with the conductor of grounding system above ground level.
- 3.03.03 The connection between each down conductor and rod electrode (by means of 40 mm mild steel rod riser) shall be made via test link located at approximately 1500 mm above ground level.
- 3.03.04 The down conductor shall be laid straight and sharp bends shall be avoided as far as practicable. These shall be cleated on outside of the building wall and column/structure at about 750 mm intervals unless stated otherwise in the drawing.
- 3.03.05 At all supports for down conductor along the column/wall of the buildings; the portion embedded inside the building concrete should not touch the reinforcement bars.
- 3.03.06 All exposed metallic parts of the buildings shall be bonded to the down conductors. Such parts shall include ladders, balconies, conduits etc.
- 3.03.07 The down conductors shall be protected at the ground level against mechanical injury by means of non-metallic pipes, viz. PVC pipes filled with bituminous compound.
- 3.04.00 **Electrodes (for Lightning Protection)**
- 3.04.01 The electrodes shall be 40 mm diameter 3000 mm long mild steel rod. These shall be driven into the ground.
- 3.04.02 All the electrodes shall be interconnected by means of one (1) 40 mm dia mild steel rod which shall be laid under ground at a minimum depth of 1000 mm below finished grade level unless stated otherwise. This ground mats/electrode in turn shall be connected to main grounding grid.
- 3.05.00 **Riser (for Lightning Protection)**

		Mantra Udyog
--	--	--------------

	Odisha Power Generation Corporation Ltd.	Technical Specification for Workshop Package	IB TPS – 2 X 660 MW Units 3 & 4, Jharsuguda, Odisha
---	--	--	---

ANNEXURE-B

3.05.01 All risers connected to grounding mat shall be 40 mm mild steel rods and shall be projected 300 mm above grade level unless stated otherwise.

3.06.00 Jointing & Connection

3.06.01 All ground conductor connections below ground level shall be done by electric arc welding with low hydrogen content electrode.

3.06.02 The projected portion of riser above ground shall be coated with two (2) coats of bitumen paints (anti-corrosive paints) with a minimum thickness of 1 mm after connection.

3.06.03 The joints in the lightning conductors shall be kept to a minimum and there shall be no joint in the underground portions of conductors.

3.06.04 All the joints shall be done by arc welding process overlapping of the conductors at straight joints shall not be less than 150 mm. The contact surfaces shall be cleaned properly before jointing.

3.06.05 The portion of galvanised steel flats, which undergoes welding at site, shall be coated with two (2) coats of cold galvanising anti-corrosive paint after welding.

3.06.06 The bolted joint of the test link shall be covered with thick coating of bitumen paint after successful testing.

3.06.07 The air terminal rods and shielding mast shall be coated with weather resistant anti-corrosive paint (zinc chromate followed by two coats of aluminium paint).

3.06.08 The steel to copper connection shall be brazed type.

3.07.00 Lightning Protection of Other areas

3.07.01 The lightning protection of other areas (ACW pump house, DG building, Compressor house, Fuel oil pump house, Mill Building, CPU Regeneration building, Condensate Transfer pump house and Mill reject system compressor house), if required shall be provided with horizontal conductors (25 x 3 mm G.S. Flat) run along the length of these areas. This conductor shall be connected to riser and grounding electrode (40 mm dia G.S. Rods) at an approximate interval of 30 mm through two down conductors (each 25 x 3 mm G.S. Flats).

3.08.00 The sizes and materials of earthing conductors to be used in lightning protection system are listed below:

DESCRIPTION	SIZE	MATERIAL
		Mantra Udyog

	Odisha Power Generation Corporation Ltd.	Technical Specification for Workshop Package	IB TPS – 2 X 660 MW Units 3 & 4, Jharsuguda, Odisha
--	--	--	---

		ANNEXURE-B	
a)	Vertical Air Termination	20 mm dia Rod	Galvanised steel
b)	Horizontal Conductor	i) 50 x 6 mm Flat	- Do -
		ii) 25 x 3 mm Flat	- Do -
c)	Down Conductors	i) 50 x 6 mm Flat	- Do -
		ii) 25 x 3 mm Flat	- Do -
d)	Riser From Electrode/ Grounding Mat	40 mm dia Rod	Mild Steel
e)	Electrode for Lightning Protection	40 mm dia Rod 3000 mm long	- Do -

NOTE :

In addition to above, all materials as required such as G.I. pipes of appropriate length, diameter and thickness shall be provided for lightning masts of Power House building and other buildings in main plant area.