			RISSA POWER GENERATION CO										
		ARD IDENT	TIFICATION & RISK ASSESSMENT (O				Υ)						
	FORMAT REVISION NO: 02/00	DATE: 11.12.08		DOCUMENT REVISION STATUS: R-				DOCUMENT REVISION DA					TE:
SI. NO	ACTIVITIES	OCCURREN CE OF HAZARDS	HAZARDS	RISKS		EVALUATION OF RISK							
					QUALITATIVE QUANTITATIVE RPN S/					S/NS	Reference		
		N/AB/E					IPC	Α	В	С			
1	Cleaning activities	N	Exposure to dust	Respiratory problems	N	N	N	6	10	3	180	NS	
		AB	Exposure to micro organisms / bacteria during cleaning or repair of toilets / urinals / pipelines		N	N	N	6	10	3	180	NS	
2	Concreting work	AB	Fall from height	Injury	N	N	N	4	50	3	600	S	
		N	Exposure to dust	Respiratory problems	N	N	N	6	10	3	180	NS	
		N	Contact with concrete	Skin irritation	Ν	N	N	6	2	3	36	NS	
		N	Exposure to dust(cement)	Eye irritation	Ν	N	N	4	5	5	100	NS	
3	Earth excavation in foundation/ trench/ pit	AB	Collapsing of earth	Injury	N	N	N	8	2	3	48	NS	
		N	Exposure to dust	Respiratory problems	Ν	N	N	6	10	3	180	NS	
4	Movement of Dumpers/ Dozers/ tractors/ tankers & other heavy vehicles during working hour	AB	Exposure to noise>85db during running of vehicles	Hearing impaired	N	N	N	2	2	5	20	NS	
		N	Exposure to vehicular emission during working of heavy vehicles & machineries	Physical Discomfort,Eye injury	N	N	N	4	5	5	100	NS	
5	Performing High & Medium risk jobs	N	Hazards due to performing the jobs without JSA, Job briefing and adequate supervision		N	N	Υ	4	50	3	600	S	
6	Stacking of construction materials at work site	AB	Road accident due to dumping of construction material and work on road	Injury	N	N	N	4	30	3	360	S	
7	Transportation of Materials	AB	Faliure of vehicle due to overloading/unsafe dtiving /mechanical failure	Accident	N	N	N	3	20	3	90	NS	