



**ODISHA POWER GENERATION CORPORATION LIMITED**  
**IB THERMAL POWER STATION**  
**At/PO: BANHARPALI, DIST: JHARSUGUDA – 768 234 (ODISHA)**

**CORRIGENDUM NOTICE-I; Dt. 05.01.2019**

**To**

**NIT No.2018-19/29(P);dt.11.10.2018**

**PURCHASE TENDER:** (Telephone; 06645-289354/356; Telefax: (06645) 289 355)

**Email:** [purchase@opgc.co.in](mailto:purchase@opgc.co.in) ; [bkmishra@opgc.co.in](mailto:bkmishra@opgc.co.in); [bhadoo.jojowar@opgc.co.in](mailto:bhadoo.jojowar@opgc.co.in); [bn.das@opgc.co.in](mailto:bn.das@opgc.co.in); .

**(A) :** This is to bring to the notice of all intending prospective bidders through this Corrigendum Notice-I to **NIT No.2018-19/29(P), dt.16.11.2018** that **the technical Specification** vide at “**ANNEXURE-I**” of the bid document is amended as given below and a revised bid document is uploaded accordingly in OPGC website. Bidders are requested to down load the same bid document and submit their bids. However, those who have already submitted, may also review their bids if it is in line with the revised specification and may like to change or keep it without any change shall intimate the undersigned and confirm through written letter in their own company letter pad or else the offer submitted by them shall be considered and opened for evaluation.

**(B): Bid submission / opening dates** has been extended as per the details in the table given herein.

**:- ANNEXURE-I:-**

**Technical specification (Amended)**

Sl. No.	Item name with part no.	Item details for Air preheater baskets	Qty. in nos.
1	Hot end basket type D	APH Type: Bisector Regenerative, Size:27VIM 2000 <b>Hot end basket type D</b> Hot/Intermediate End Baskets: Element Type DU (24 Gauge), Height: 850mm, Material: Carbon steel.	48
2	Hot end basket type E	APH Type: Bisector Regenerative, Size:27VIM 2000 <b>Hot end basket type E</b> Hot/Intermediate End Baskets: Element Type DU (24 Gauge), Height: 850mm, Material: Carbon steel.	48
3	Hot end basket type F	APH Type: Bisector Regenerative, Size:27VIM 2000 <b>Hot end basket type F</b> Hot/Intermediate End Baskets: Element Type DU (24 Gauge), Height: 850mm, Material: Carbon steel.	48
4	Hot end basket inter type G27	APH Type: Bisector Regenerative, Size:27VIM 2000 <b>Hot end basket inter type G27</b> Hot/Intermediate End Baskets: Element Type DU (24 Gauge), Height:850mm, Material: Carbon steel.	60
5	Assy. of cold end basket type DC	APH Type: Bisector Regenerative, Size:27VIM 2000 <b>Assy. of cold end basket type DC</b> Cold End Baskets: Element Type DU(22 Gauge),Height:300mm, Material: Corten A.	72
6	Assy. of cold end basket type E	APH Type: Bisector Regenerative, Size:27VIM 2000 <b>Assy. of cold end basket type E</b> Cold End Baskets: Element Type DU(22 Gauge),Height:300mm, Material: Corten A.	48
7	Assy. of cold end basket type F27	APH Type: Bisector Regenerative, Size:27VIM 2000 Assy. of cold end basket type F27 Cold End Baskets: Element Type DU(22 Gauge),Height:300mm, Material: Corten A.	48
8	Assy. of cold end basket type FC27	APH Type: Bisector Regenerative, Size:27VIM 2000 <b>Assy. of cold end basket type FC27</b> Cold End Baskets: Element Type DU(22 Gauge),Height:300mm, Material: Corten A.	48

9	Assy. of cold end basket type AB	APH Type: Bisector Regenerative, Size:27VIM 2000 <b>Assy. of cold end basket type AB</b> Cold End Baskets: Element Type DU22 Gauge),Height:300mm, Material: Corten A.	10
10	Assy. of cold end basket type C	APH Type: Bisector Regenerative, Size:27VIM 2000 <b>Assy. of cold end basket type C</b> Cold End Baskets: Element Type DU(22 Gauge),Height:300mm, Material: Corten A.	10
11	Assy. of cold end basket type D	APH Type: Bisector Regenerative, Size:27VIM 2000 <b>Assy. of cold end basket type D</b> Cold End Baskets: Element Type DU(22 Gauge),Height:300mm, Material: Corten A.	10

**NB: 1. Interested bidders may visit to our site and take the measurement and get themselves clarified about the technical details of required items. by seeing it physically before they submit their offers. They need to develop their drawing and get it approved by the authority of OPGC before manufacturing.**

**2. Please mention the weight of each item quoted.**

**(B). Bid submission /opening date- (Revised):**

<i>Tender No.</i>	<i>Description</i>	<i>Bid Sale / Issue date</i>	<i>Bid receipt / Opening</i>	<i>Bid Type</i>
<i>NIT No. ITPS/Purchase/ 2018-19/ 29(P), Dt.16-11- -2018</i>	<i>Supply of Air preheater baskets for both cold &amp; hot end to IB Thermal Power Station</i>	<i>01-12-2018 to 10-01-2019</i>	<i>21-01-2019 / 21-01-2019</i>	<i>Two Bid</i>

**N.B: All other stipulations/conditions of the NIT-07(P), Dt.20.08.2016 shall remain unaltered.**

**Sd./- DGM -SCM**

**(Email: bkmishra@opgc.co.in; Landline No. 06645-289703)**

**SAFE & CLEAN POWER IS OUR COMMITMENT**