



ODISHA POWER GENERATION CORPORATION LIMITED
IB THERMAL POWER STATION
At/PO: BANHARPALI, DIST: JHARSUGUDA – 768 234 (ODISHA)

CORRIGENDUM NOTICE-II; Dt.24.09.2018
(To NIT No. 2018-19/14(P), Dt.05.06.2018)

PURCHASE TENDER ;

(Telephone; 06645-289354/356; Telefax: (06645)289355 Email: purchase@opgc.co.in; bhadoa.jojowar@opgc.co.in; bn.das@opgc.co.in ;)

This is to bring to the notice of all intending prospective bidders through this **Corrigendum Notice** that the extended bid submission & opening date and the revised technical details in addition to the specification mentioned in the bid document against the following NIT is as here under.

(A) EXTENSION OF BID SUBMISSION & OPENING:

| Sl. No | NIT No/Date | Description | Qty. | Due date of bid submission /opening | Extended Bid submission/ Opening Date. | Single bid / two bid |
|--------|---|------------------------|-------|-------------------------------------|--|----------------------|
| 3 | NIT No : ITPS/Purchase/ 2018-19/14 (P), dt.05/06/2018 | Supply of 185 KW motor | 01 no | 03.09.2018/ 03.09.2018 | 25.10.2018/ 25.10.2018 | Two bid |

(i) Time of submission/Receipt of bids: up to 15:00Hrs; (ii) Time of Bid Opening: 15:30Hrs.

(B) REVISED DETAILED SPECIFICATION:

| Sl. No. | Item description | Quantity |
|---------|--|----------|
| 1 | 185 KW Motor is Squirrel Cage Type, Insulation Class-F & Load to be driven is mainly an air compressor (Screw type) for Pneumatic Ash Conveying. Detail technical Specification: a) Motor capacity - 185KW b) Induction motor,6600 volts, 3-Phase, 50Hz, 20.5 Amps, c) Frame-DC315F800,Type-FLOWPAK, d) RPM-1489 e) Mounting of the Motor: B-3, Type Mounting. f) Starting method of the motor : DOL with 6.6KV VCB g) Duty of the motor: S1 with Continuous Duty h) Construction : Squirrel Cage Type i) Insulation: Class-F In addition to above, other relevant technical information are as here below: - i. MOI: 25 Kg/Sqm ii. IP-55 iii. Efficiency : 94% iv. Type: FLOWPAK | 01 no |

NB: Supplier has to Perform all Type & Routine Test at the Time of manufacturing the Motor. Type & Routine Test details to be shared with us (OPGCL) in proper Format (Manufacturer's Quality Assurance plan QAP) & Report of the same shall be submitted before dispatch.

N.B: All other stipulations/conditions of the NIT-14(P), Dt.05.06.2018 shall remain unaltered.

Sd./- AGM - SCM

(Email: bkmishra@opgc.co.in; Landline No. 06645-289703)

SAFE & CLEAN POWER IS OUR COMMITMENT