			RISSA POWER GENERATION CO											
		ARD IDENT	IFICATION & RISK ASSESSMENT (O DATE: 11.12.08				Υ)							
	FORMAT REVISION NO: 02/00	DOCUMENT REVISION STATUS : R- DOCUMENT REVISION DATE :								TE:				
SI. NO	ACTIVITIES	OCCURREN CE OF HAZARDS		RISKS		EVALUATION OF RISK								
									QUANTITATIVE			S/NS	Reference	
		N/AB/E			LC	BC	IPC	Α	В	С				
1	Cleaning activities	N	Exposure to dust	Respiratory problems	N	N	N	6	10	3	180	NS		
			Exposure to micro organisms / bacteria during cleaning or repair of toilets / urinals / pipelines		N	N	N	6	10	3	180	NS		
2	Concreting work , Masonary Work, Tile work	AB	Fall from height	Injury	N	N	N	4	50	3	600	S		
		N	Exposure to dust	Respiratory problems	N	N	N	6	10	3	180	NS		
		N	Contact with concrete	Skin irritation	N	N	N	6	2	3	36	NS		
		N	Exposure to dust(cement)	Eye irritation	N	N	N	4	5	5	100	NS		
3	Earth excavation in foundation/ trench/pit	AB	Collapsing of earth	Injury	N	N	N	8	2	3	48	NS		
		N	Exposure to dust	Respiratory problems	N	N	N	6	10	3	180	NS		
4	Movement of Dumpers/ Dozers/ tractors/ tankers & other heavy vehicles during working hour	AB	Exposure to noise>85db during running of vehicles	Hearing impaired	N	N	N	2	2	5	20	NS		
			Exposure to vehicular emission during working of heavy vehicles & machineries	Physical Discomfort,Eye injury	N	N	N	4	5	5	100	NS		
5	Performing High & Medium risk jobs	N	Hazards due to performing the jobs without JSA, Job briefing and adequate supervision	Fatality/ Injury	N	N	Y	4	50	3	600	S		
6	Stacking of construction materials at work site		Road accident due to dumping of construction material and work on road	Injury	N	N	N	4	30	3	360	S		
7	Transportation of Materials	AB	Faliure of vehicle due to overloading/unsafe dtiving /mechanical failure	Accident	N	N	N	3	20	3	90	NS		